



142 N. Ohio Drive • Celina, Texas 75009 • Phone 972.382.2682 • Fax 972.382.3736

## IRRIGATION CHECK LIST

1. Permit application.
2. (2) 11" x 17" Plot Plans showing the following:
  - a. Location of Water Meter
  - b. Isolation Valve ("size") (Ball Valve)
  - c. Wye Strainer
  - d. Backflow Device (DC)
  - e. Master Valve (Control Valve)
  - f. **Rain/Freeze Sensor:** Recommended to be located on the West side or North side of the house. Preferably located on the fence.
  - g. Rules for lawn irrigation and irrigation systems
  - h. All new irrigation systems are required to include rain and freeze sensors, capable of multiple programming.
  - i. All new irrigation systems are required to be in compliance with state design and installation regulations (TAC Title 30, Part 1, Chapter 344).
  - j. Irrigation systems that spray directly onto impervious surfaces or onto other non-irrigated areas are prohibited. (Wind driven water drift will be taken into consideration).
  - k. No person or facility or operation shall cause or permit the flow of excess or fugitive water onto any adjacent property or public right-of-way.

