



142 N. Ohio Drive • Celina, Texas 75009 • Phone 972.382.2682 • Fax 972.382.3736

IRRIGATION CHECK LIST

1. Email application and PDF plans to: permits@celina-tx.gov
2. Plans shall show the following:
 - A. Location of Water Meter
 - B. Isolation Valve (size) (Ball Valve)
 - C. Wye Strainer
 - D. Backflow device (DC)
 - E. Master Valve (Control Valve)
 - F. Rain / Freeze Sensors
 - G. Rules for Lawn Irrigation and Irrigation systems
 - H. All new Irrigation systems are required to include rain and freeze sensors capable of multiple programming
 - I. All new Irrigation systems are required to be in compliance with State design and installation regulations (TAC Title 30, Part 1, Chapter 344)
 - J. Irrigation systems that spray directly onto impervious surfaces or onto other non-irrigated areas are prohibited (Wind driven water drift will be taken into consideration)
 - K. No person or facility or operation shall cause or permit the flow of excess or fugitive water onto any adjacent property or public right-of-way.

