



Life Connected.

This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on application process.

*** Homeowners' or Property Owners' Association approvals are required and shall be obtained PRIOR to submitting an application with the City***

We are a paperless office Please Submit Your Project Request through Your MyGov account. If you are a Homeowner, you may email it to Permits@Celina-TX.Gov

Pool Permit

INFORMATION NEEDED FOR SUBMITTAL:

- Residential Permit Application (required with all project requests)
- HOA approval letter (if applicable)
- Collin or Denton County stamp on every plan (if septic system)
- Electrical company stamp on every plan (**no** review without it)
- Fence details (location, height, material, gate self-close/latch swing outward)
 - Wood: Horizontal members inside. "pool side"
 - Iron: must have 45" between horizontal members
- Plans 2018 IRC, 2018 IECC, Chapter 11 Energy, 2020 NEC Commercial, 2018 IBC
- Survey
 - Pools/decks cannot encroach in easements
- Show path for excavation equipment
 - Provide letter from owner of any other property if needed

RESTRICTIONS:

- All pools/spas and above ground pools over 24" deep require a permit.
- Pools/spas shall be located no closer than 5 feet from pool's edge to all property lines. There must be a one-to-one ratio from foundation, property lines or retaining walls to pool's edge.
- Pools within 5 feet from pool's edge to existing foundations or retaining walls, shall require an engineered sealed plan, and an inspection report stating the requirements of design engineer on excavation and plan requirements have been approved by design engineer.
- Fence detail must be included to show either existing fence or proposed fence location and compliance with fence barrier requirements around pool.
- Every swimming pool or excavation site designed or intended to ultimately become a swimming pool, shall be continuously protected by an enclosure surrounding the pool or excavated area that is reasonably inaccessible to small children or animals.
- Pool or decking must not encroach in any easement on property, concrete or decks must maintain 3-foot setback from property lines.
- All disturbed grass must have sod replaced.
- The certification of the pool protection device installation form must be provided prior to FINAL INSPECTION.



This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on application process.

Life Connected.

- P-Trap and backwash line inspection required on all areas, if cartridge filter is provided P-Trap is still required, although no backwash line, will be required.
- Shall not be located in the front yard area
- Shall comply with the minimum side yard and corner lot requirements for accessory structures.
- Heated pools or spas shall comply with 2018 IRC Chapter 11- N1103.10 or 2018 IECC - R (Energy Code) on the following:
 - Heaters – N1103.10.1 or R403.10.1
 - Time switches – N1103.10.2 or R403.10.2
 - Covers – Vapor - retardant cover – N1103.10.3 or R403.10.3

CONTRACTOR REQUIREMENTS:

- All Generator installers are required to be registered with the City of Celina as General Contractors **and** Pool contractors.
- All project requests will be submitted through myGov and are subject to review

REQUIRED INSPECTIONS:

- Pool belly steel and Bonding
- Electrical Underground
- Pool deck steel
- Pool gas
- Pool p-trap
- Pool final



Life Connected.

This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on application process.

SECTION 101 GENERAL

[A] **101.1 Title.** These regulations shall be known as the Swimming Pool and Spa Code of The City of Celina, hereinafter referred to as “this code.”

[A] **101.2 Scope.** The provisions of this code shall apply to the construction, alteration, movement, renovation, replacement, repair and maintenance of aquatic recreation facilities, pools, and spas. The pools and spas covered by this code are either permanent or temporary and shall be only those that are designed and manufactured to be connected to a circulation system and that are intended for swimming, bathing or wading.

101.2.1 Flotation tanks. Flotation tank systems intended for sensory deprivation therapy shall not be considered to be included in the scope of this code.

[A] **101.3 Intent.** The purpose of this code is to establish minimum standards to provide a reasonable level of safety and protection of health, property and public welfare by regulating and controlling the design, construction, installation, quality of materials, location and maintenance or use of pools and spas.

SECTION 102 APPLICABILITY

[A] **102.1 General.** Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern.

SECTION 106 INSPECTIONS

[A] **106.1 General.** Construction or work for which a permit is required shall be subject to inspection by the code official and such construction or work shall remain visible and able to be accessed for inspection purposes until *approved*. Approval as a result of an inspection shall not be construed to be an approval of a violation of the provisions of this code or of other ordinances of the jurisdiction. Inspections presuming to give authority to violate or cancel the provisions of this code or of other ordinances of the jurisdiction shall not be valid. It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Neither the code official nor the jurisdiction shall be liable for expense entailed in the removal or replacement of any material required to allow inspection.

SECTION 302

ELECTRICAL, PLUMBING, MECHANICAL AND FUEL GAS REQUIREMENTS

302.4 Concealed piping inspection. Piping, including process piping, that is installed in trenches, shall be inspected prior to backfilling.

302.5 Backflow protection. Water supplies for pools and spas shall be protected against backflow in accordance with the *International Plumbing Code* or the *International Residential Code*, as applicable in accordance with Section

BUILDING PERMITS
permits@celina-tx.gov
972-382-2111

CITY OF CELINA
Attention Permits
142 N. Ohio St
Celina, Texas 75009



This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on application process.

102.7.1.

Life Connected

302.6 Wastewater discharge. Where wastewater from pools or spas, such as backwash water from filters and water from deck drains discharge to a building drainage system, the connection shall be through an air gap in accordance with the *International Plumbing Code* or the *International Residential Code* as applicable in accordance with Section 102.7.1.

SECTION 303 ENERGY

303.1 Energy consumption of pools and permanent spas. The energy consumption of pools and permanent spas shall be controlled by the requirements in Sections 303.1.1 through 303.1.3.

303.1.3 Covers. Outdoor heated pools and outdoor permanent spas shall be provided with a vapor-retardant cover or other *approved*

vapor-retardant means in accordance with Section 104.11.

Exception: Where more than 70 percent of the energy for heating, computed over an operating season, is from a heat pump or solar energy source, covers or other vapor-retardant means shall not be required.

303.2 Portable spas. The energy consumption of electric powered portable spas shall be controlled by the requirements of APSP 14.

303.3 Residential pools and permanent residential spas. The energy consumption of *residential* swimming pools and permanent

residential spas shall be controlled in accordance with the requirements of APSP 15.

SECTION 305 BARRIER REQUIREMENTS

305.1 General. The provisions of this section shall apply to the design of barriers for restricting entry into areas having pools and spas. Where spas or hot tubs are equipped with a lockable safety cover complying with ASTM F1346 and swimming pools are equipped with a powered safety cover that complies with ASTM F1346, the areas where those spas, hot tubs or pools are located shall not be required to comply with Sections 305.2 through 305.7.

305.2 Outdoor swimming pools and spas. Outdoor pools and spas and indoor swimming pools shall be surrounded by a barrier that complies with Sections 305.2.1 through 305.7.



Swimming Pool and Spa

*****Association approvals are required and shall be obtained PRIOR to project request*****

****Request your project through your MyGov account.**

Submittal is required to be in one single PDF file uploaded to your project at the time of submittal.

This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on the application and inspection process.

SECTION 101 GENERAL

[A] 101.1 Title. These regulations shall be known as the Swimming Pool and Spa Code of The City of Celina, hereinafter referred to as “this code.”

[A] 101.2 Scope. The provisions of this code shall apply to the construction, alteration, movement, renovation, replacement, repair and maintenance of aquatic recreation facilities, pools, and spas. The pools and spas covered by this code are either permanent or temporary and shall be only those that are designed and manufactured to be connected to a circulation system and that are intended for swimming, bathing or wading.

101.2.1 Flotation tanks. Flotation tank systems intended for sensory deprivation therapy shall not be considered to be included in the scope of this code.

[A] 101.3 Intent. The purpose of this code is to establish minimum standards to provide a reasonable level of safety and protection of health, property and public welfare by regulating and controlling the design, construction, installation, quality of materials, location and maintenance or use of pools and spas.

SECTION 102 APPLICABILITY

[A] 102.1 General. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern.

SECTION 106 INSPECTIONS

[A] 106.1 General. Construction or work for which a permit is required shall be subject to inspection by the code official and such construction or work shall remain visible and able to be accessed for inspection purposes until *approved*. Approval as a result of an inspection shall not be construed to be an approval of a violation of the provisions of this code or of other ordinances of the jurisdiction. Inspections presuming to give authority to violate or cancel the provisions of this code or of other ordinances of the jurisdiction shall not be valid. It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Neither the code official nor the jurisdiction shall be liable for expense entailed in the removal or replacement of any material required to allow inspection.

SECTION 302

ELECTRICAL, PLUMBING, MECHANICAL AND FUEL GAS REQUIREMENTS

302.4 Concealed piping inspection. Piping, including process piping, that is installed in trenches, shall be inspected



Swimming Pool and Spa

*****Association approvals are required and shall be obtained PRIOR to project request*****

****Request your project through your MyGov account.**

Submittal is required to be in one single PDF file uploaded to your project at the time of submittal.

This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on the application and inspection process.

prior to backfilling.

302.5 Backflow protection. Water supplies for pools and spas shall be protected against backflow in accordance with the *International Plumbing Code* or the *International Residential Code*, as applicable in accordance with Section 102.7.1.

302.6 Wastewater discharge. Where wastewater from pools or spas, such as backwash water from filters and water from deck drains discharge to a building drainage system, the connection shall be through an air gap in accordance with the *International Plumbing Code* or the *International Residential Code* as applicable in accordance with Section 102.7.1.

SECTION 303 ENERGY

303.1 Energy consumption of pools and permanent spas. The energy consumption of pools and permanent spas shall be controlled by the requirements in Sections 303.1.1 through 303.1.3.

303.1.3 Covers. Outdoor heated pools and outdoor permanent spas shall be provided with a vapor-retardant cover or other *approved*

vapor-retardant means in accordance with Section 104.11.

Exception: Where more than 70 percent of the energy for heating, computed over an operating season, is from a heat pump or solar energy source, covers or other vapor-retardant means shall not be required.

303.2 Portable spas. The energy consumption of electric powered portable spas shall be controlled by the requirements of APSP 14.

303.3 Residential pools and permanent residential spas. The energy consumption of *residential* swimming pools and permanent

residential spas shall be controlled in accordance with the requirements of APSP 15.

SECTION 305 BARRIER REQUIREMENTS

305.1 General. The provisions of this section shall apply to the design of barriers for restricting entry into areas having pools and spas. Where spas or hot tubs are equipped with a lockable safety cover complying with ASTM F1346 and swimming pools are equipped with a powered safety cover that complies with ASTM F1346, the areas where those spas, hot tubs or pools are located shall not be required to comply with Sections 305.2 through 305.7.

305.2 Outdoor swimming pools and spas. Outdoor pools and spas and indoor swimming pools shall be surrounded by a barrier that complies with Sections 305.2.1 through 305.7.

305.2.1 Barrier height and clearances. Barrier heights and clearances shall be in accordance with all of the following:

Swimming Pool and Spa

Association approvals are required and shall be obtained PRIOR to project request

**Request your project through your MyGov account.

Submittal is required to be in one single PDF file uploaded to your project at the time of submittal.

This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on the application and inspection process.

1. The top of the barrier shall be not less than 48 inches (1219 mm) above grade where measured on the side of the barrier that faces away from the pool or spa. Such height shall exist around the entire perimeter of the barrier and for a distance of 3 feet (914 mm) measured horizontally from the outside of the required barrier.
2. The vertical clearance between grade and the bottom of the barrier shall not exceed 2 inches (51 mm) for grade surfaces that are not solid, such as grass or gravel, where measured on the side of the barrier that faces away from the pool or spa.
3. The vertical clearance between a surface below the barrier to a solid surface, such as concrete, and the bottom of the required barrier shall not exceed 4 inches (102 mm) where measured on the side of the required barrier that faces away from the pool/spa.
4. Where the top of the pool or spa structure is above grade, the barrier shall be installed on grade or shall be mounted on top of the pool or spa structure. Where the barrier is mounted on the top of the pool or spa, the vertical clearance between the top of the pool or spa and the bottom of the barrier shall not exceed 4 inches (102 mm).

305.2.2 Openings. Openings in the barrier shall not allow passage of a 4-inch-diameter (102 mm) sphere.

305.2.3 Solid barrier surfaces. Solid barriers that do not have openings shall not contain indentations or protrusions that form handholds and footholds, except for normal construction tolerances and tooled masonry joints.

305.2.4 Mesh fence as a barrier. Mesh fences, other than chain link fences in accordance with Section 305.2.7, shall be installed in accordance with the manufacturer's instructions and shall comply with the following:

1. The bottom of the mesh fence shall be not more than 1 inch (25 mm) above the deck or installed surface or grade.
2. The maximum vertical clearance from the bottom of the mesh fence and the solid surface shall not permit the fence to be lifted more than 4 inches (102 mm) from grade or decking.
3. The fence shall be designed and constructed so that it does not allow passage of a 4-inch (102 mm) sphere under any mesh panel. The maximum vertical clearance from the bottom of the mesh fence and the solid surface shall be not greater than 4 inches (102 mm) from grade or decking.
4. An attachment device shall attach each barrier section at a height not lower than 45 inches (1143 mm) above grade. Common attachment devices include, but are not limited to, devices that provide the security equal to or greater than that of a hook-and-eye-type latch incorporating a spring-actuated retaining lever such as a safety gate hook.
5. Where a hinged gate is used with a mesh fence, the gate shall comply with Section 305.3.
6. Patio deck sleeves such as vertical post receptacles that are placed inside the patio surface shall be of a non-conductive material.
7. Mesh fences shall not be installed on top of on-ground residential pools.

305.2.5 Closely spaced horizontal members. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members shall be located on the pool or spa side of the fence. Spacing between vertical members shall not exceed 13/4 inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts shall not exceed 13/4 inches (44 mm) in width.

305.2.6 Widely spaced horizontal members. Where the barrier is composed of horizontal and vertical members and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing between vertical members shall not exceed 4 inches (102 mm). Where there are decorative cutouts within vertical members, the interior

Swimming Pool and Spa

Association approvals are required and shall be obtained PRIOR to project request

**Request your project through your MyGov account.

Submittal is required to be in one single PDF file uploaded to your project at the time of submittal.

This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on the application and inspection process.

width of the cutouts shall not exceed 13/4 inches (44 mm).

305.2.8 Diagonal members. Where the barrier is composed of diagonal members, the maximum opening formed by the diagonal members shall be not greater than 13/4 inches (44 mm). The angle of diagonal members shall be not greater than 45 degrees (0.79 rad) from vertical.

305.2.9 Clear zone. There shall be a clear zone of not less than 36 inches (914 mm) between the exterior of the barrier and any permanent structures or equipment such as pumps, filters and heaters that can be used to climb the barrier.

305.2.10 Poolside barrier setbacks. The pool or spa side of the required barrier shall be not less than 20 inches (508 mm) from the water's edge.

305.3 Gates. Access gates shall comply with the requirements of Sections 305.3.1 through 305.3.3 and shall be equipped to accommodate a locking device. Pedestrian access gates shall open outward away from the pool or spa, shall be self-closing and shall have a self-latching device.

305.3.1 Utility or service gates. Gates not intended for pedestrian use, such as utility or service gates, shall remain locked when not in use.

305.3.2 Double or multiple gates. Double gates or multiple gates shall have not fewer than one leaf secured in place and the adjacent leaf shall be secured with a self-latching device. The gate and barrier shall not have openings larger than 1/2 inch (12.7 mm) within 18 inches (457 mm) of the latch release mechanism. The self-latching device shall comply with the requirements of Section 305.3.3.

305.3.3 Latches. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from grade, the release mechanism shall be located on the pool or spa side of the gate not less than 3 inches (76 mm) below the top of the gate, and the gate and barrier shall not have openings greater than 1/2 inch (12.7 mm) within 18 inches (457 mm) of the release mechanism.

305.4 Structure wall as a barrier. Where a wall of a dwelling or structure serves as part of the barrier and where doors or windows provide direct access to the pool or spa through that wall, one of the following shall be required:

1. Operable windows having a sill height of less than 48 inches (1219 mm) above the indoor finished floor and doors shall have an alarm that produces an audible warning when the window, door or their screens are opened. The alarm shall be listed and labeled as a water hazard entrance alarm in accordance with UL 2017. In dwellings or structures not required to be Accessible units, Type A units or Type B units, the operable parts of the alarm deactivation switches shall be located 54 inches (1372 mm) or more above the finished floor. In dwellings or structures required to be Accessible units, Type A units or Type B units, the operable parts of the alarm deactivation switches shall be located not greater than 54 inches (1372 mm) and not less than 48 inches (1219 mm) above the finished floor.
2. A safety cover that is listed and labeled in accordance with ASTM F1346 is installed for the pools and spas.
3. An approved means of protection, such as self-closing doors with self-latching devices, is provided. Such means of protection shall provide a degree of protection that is not less than the protection afforded by Item 1 or 2.

305.5 On-ground residential pool structure as a barrier. An on-ground residential pool wall structure or a barrier mounted on top of an on-ground residential pool wall structure shall serve as a barrier where all of the following conditions are present:



Swimming Pool and Spa

*****Association approvals are required and shall be obtained PRIOR to project request*****

****Request your project through your MyGov account.**

Submittal is required to be in one single PDF file uploaded to your project at the time of submittal.

This outline is not intended to be an all-inclusive reflection of all regulations. It is designed to provide guidance on the application and inspection process.

1. Where only the pool wall serves as the barrier, the bottom of the wall is on grade, the top of the wall is not less than 48 inches(1219 mm) above grade for the entire perimeter of the pool, the wall complies with the requirements of Section 305.2 and the pool manufacturer allows the wall to serve as a barrier.
2. Where a barrier is mounted on top of the pool wall, the top of the barrier is not less than 48 inches (1219 mm) above grade for the entire perimeter of the pool, and the wall and the barrier on top of the wall comply with the requirements of Section 305.2.
3. Ladders or steps used as means of access to the pool are capable of being secured, locked, or removed to prevent access except where the ladder or steps are surrounded by a barrier that meets the requirements of Section 305.
4. Openings created by the securing, locking or removal of ladders and steps do not allow the passage of a 4-inch(102 mm) diameter sphere.
5. Barriers that are mounted on top of on ground residential pool walls are installed in accordance with the pool manufacturer's instructions.

PERMANENT RESIDENTIAL SPAS AND PERMANENT RESIDENTIAL EXERCISE SPAS

SECTION 901 GENERAL

901.1 Scope. This chapter shall govern the design, installation, construction, and repair of permanently installed residential spas and exercise spas intended for residential use.

901.2 General. Permanent residential spas and permanent residential exercise spas shall comply with Chapter 5 except that Sections 504.1, 504.1.1, 508.1 and 509 shall not apply. Such spas shall comply with the requirements of Chapter 3.

SECTION 902 SAFETY FEATURES

902.1 Instructions and safety signage. Instructions and safety signage shall comply with the manufacturer's recommendations and the requirements of the local jurisdiction.